

Addendum 1 IWQ 20-04

Design of New Sidewalk from Parliament Drive to the Vermack Swim Club along Vermack Road

Date: 12/09/2020

Questions and Answers

- For the MS4 analysis, will survey and analysis be required of the receiving closed drainage systems? Both systems outfall into a Nancy Creek Tributary, one at the Vermack Swim Club and the other outfalls between 4880 and 4888 Vermack Road based on Dunwoody GIS.
 - Yes a downstream survey and analysis will be required.